

MEMO TO FILE

On Sunday, May 20, 1990, I received a call from the Fire Department dispatcher about a problem with gasoline in the sewer in the 2800 block of west Walnut. When I arrived there, the manhole in front of 2836 W. Walnut was being flushed by Darryl and Ron. Fire Marshal Steve Strader had been checking manholes. I also began checking manholes in the area and got the following results:

11:16 a.m. Wye map 0-5

MH 2 40% L.E.L.

MH 1 40% L.E.L.

MH 8 0% L.E.L.

MH 3 0% L.E.L.

Wye map P-5

MH 5 40% L.E.L.

MH 10 2% L.E.L.

12:46 p.m. Wye map 0-5

MH 2 50% L.E.L.

MH 1 45% L.E.L.

MH 8 0% L.E.L.

MH 3 0% L.E.L.

MH 38 0% L.E.L.

Wye map P-5

MH 5 35% L.E.L.

1:30 p.m. Wye map 0-5

MH 2 30% L.E.L. (dipped water, couldn't see sheen)

MH 1 25% L.E.L.

MH 38 0% L.E.L.

Wye map P-5

MH 5 15-20% L.E.L.

Storm sewer behind 2737 W. Olive-no odor

2:00

MH 12 0% L.E.L.

MH 2 35% L.E.L.

MH 5 20% L.E.L.

Storm sewer near MH 5-no odor

6:50 p.m.

MH 2 40% L.E.L. (dipped water, couldn't see sheen)

MH 1 40% L.E.L.

MH 38 0% L.E.L.

MH 8 0% L.E.L.

MH 5 30% L.E.L.

MH 10 0% L.E.L.

I went to the Phillips 66 Service Station on Scenic and asked the clerk if she knew of any product loss. She said she would ask the manager when she was in tomorrow. I went to the Tommy Oil Station on Scenic. The clerk there didn't know of any product loss, but said he would ask the manager tomorrow.

2800 W. WALNUT

I also went to the Git-N-Go Station on west College but the clerk there didn't know of any product loss. She said the manager would be in tomorrow.

Karen Chandler

Karen Chandler
Water Pollution Control Inspector II
Surveillance & Enforcement

Mr. Steve Short, Water Pollution Control Inspector II
Mr. Bob Corson, Water Pollution Control Inspector III
Mr. Randy Lyman, Sewer Surveillance & Billing Supervisor

2800 W. WALNUT